

Continuous Energy Management at UC San Diego



Anna Levitt, P.E.
Assistant Energy Manager
June 13, 2013

UC San Diego: A 42 megawatt Microgrid

With a daily population of over 45,000, UC San Diego is the size and complexity of a small city.

As a research and medical institution, we have two times the energy density of commercial buildings

12 million sq. ft. of buildings, \$250M/yr of building growth



UC San Diego's Climate Action Plan: The Drivers

- **Climate Goals**

- UC Goals: 2000 Levels by 2014
- AB32 Goals: 1990 Levels by 2020 and 80% Below 1990 Levels by 2050

- **The Price of Carbon**

- At least \$1-2 million per year

- **Budget Reductions**

- \$30 million per year
- UC Working Smarter Initiative

The Plan

Energy
Efficiency

Renewable
Distributed
Generation

Biogas for
Cogeneration

Energy
Storage & Grid
Management

Behavioral
Change
Campaigns

Cogeneration & Distributed Generation

Existing Cogeneration Plant
saves \$8M annually

Self generate > 85% of annual
use

- 30 MW natural gas Cogen plant
& TES
- 2.8 MW fuel cell
- 2.3 MW of Solar PV installed




Investment in Energy Efficiency

Funded by **utility incentives** and a **low interest revenue bond**

In five years, UCSD will **complete \$60M of projects**, with **\$12.8M in incentives**


Program will **yield \$6 M in avoided annual energy costs**




- Annual 15-Year Debt Service
- Annual Savings

EE Program Breakdown

by Savings



by Cost



Metering



PACIFIC HALL ENERGY USAGE

Electricity Usage

485 kW



108 kW



E1161

84 kW



E1162

677 kW

Pacific Hall Total Usage



3.67 W/sq-ft



32.1 kWh/sq-ft year



Chilled and Hot Water Energy Usage

CHW MMBTUS- HR	1.50
CHW Flow	500.18
CHW Supply Temp	45.83
CHW Return Temp	51.90

HTW MMBTUS-HR	0.68
HTW Flow	85.16
HTW Supply Temp	337.98
HTW Return Temp	320.07


Pac Hall Historical BTU Data



Monthly BTU Totals




Benchmarking




Monitoring-Based Commissioning (MBCx)


Metering & Benchmarking




HVAC Testing, Repair, & Optimization



Energy Savings



Project Delivery



Types of Findings

Findings Category	Findings	Bonner Hall	EBU-1	AP&M	CTF	CMME	CMMW	Cognitive Science	Galbraith Hall	Geisel Library	Pacific Hall	RIMAC	Stein	Sverdrup Hall	Total
Mechanical Deficiency	Valve Leak-by	4	40	9	18	2	5	1	5	41		2	0		127
	Broken Economizer Dampers		12	6	7			6	13			5	2		51
	Broken or Unnecessary Inlet Vanes							5			4		2		11
	Fan Vibration							1		5		1			7
	Steam Condensate Return to Boiler	1			1										2
	Oxidized/Dirty Coils		18		1	1		1				1			22
Controls	Sensor Calibration/Replacement	19	41	23	5	5	4	10	28	29	17	40	15	10	246
	Loop Tuning	4	48	11	7		1		19		10	3	1	3	107
	Economizer Programming		11	4	9				1		3	4			32
	Scheduling		5	2					17			1			25
	Fan/Motor Status				3		3	4	1	11	2	1	8		33
	Lead/Lag Programming							1		2	2	3	1		9
	Simultaneous Heating/Cooling				11			1				1	3		16
	E/P Card or DDC Connectivity Issues	5	27	4		1	2	11	4	13	11	4	1		83
	Pump Reset Implementation	2		1		1	1		7	2			4		18
Supply Air Temperature and Static Pressure Resets	3		2	8	14		5	5	3	8	5	2		55	
Electrical	VFD Installation/Repair	1	13	3		1	2	4	6	1		9	9	2	51
	Electrical Breaker Issues						1	1							2
General Maintenance	Belt/Sheave Maintenance		13	5	5	1	2	6	2	6	3	6	1	2	52
	Filter Maintenance		14		7	9	9	1	2	3	7	5	5	2	64
	Duct Leakage	1	1	4	2		1	2	1	3	5	3	3		26
	Missing Insulation		4		5		1			4	2	2			18
	Condensate Pan Clogged or Not Draining		18		1		1	1	1	7		2	1		32

Types of Fixes

Measure	Number of Instances	Average Savings per Instance	Total Potential Savings	Labor Hours	Labor Cost *	Material Costs	Simple Payback (Years)
Loop Tuning	107	\$ 480	\$ 51,360	26	\$1,950	\$0	4.1
Economizer Repair**	42	\$ 1,540	\$ 64,680	32	\$2,400	\$2,000	2.9
Campus Standard Setpoints	6	\$ 1,530	\$ 9,180	16	\$1,200	\$0	0.8
Repairing Leaking or Non-Operating Valves	143	\$ 1,680	\$ 240,240	10	\$750	\$1,200	1.2
Scheduling	25	\$ 5,740	\$ 143,500	4	\$300	\$0	0.1
Supply Air Temperature and Static Pressure Resets	55	\$ 1,280	\$ 70,400	40	\$3,000	\$0	2.3
Differential Pressure Resets	18	\$ 230	\$ 4,140	14	\$1,050	\$0	4.6
Adding AHU VFDs	27	\$ 9,340	\$ 252,180	78	\$5,850	\$7,500	1.4
Adding Pump VFDs	10	\$ 11,200	\$ 112,000	12	\$900	\$7,501	0.8
Condensate Return	2	\$ 4,410	\$ 8,820	10	\$750	\$2,500	0.7

****Each economizer may have multiple issues to in need of repair, so 2 issues per economizer are assumed.**

MBCx Project Results

	2011	2012	2013 (so far)	Total
No. of Projects	4	4	2	10
kWh/yr	874,373	1,544,071	892,444	3,310,888
therms/yr	118,280	222,656	195,245	536,181
savings	\$ 212,560	\$ 387,905	\$ 284,766	\$ 885,231
incentive	\$ 328,130	\$ 593,233	\$ 409,432	\$ 1,330,794
cost	\$ 1,170,833	\$ 1,686,369	\$ 1,109,923	\$ 3,967,124
simple payback (yrs)	4.0	2.8	2.5	3.0

- Simple Paybacks: 7 months to 16.9 years
- Total Cost: \$2.30 to \$6.13 per GSF
- Metering: 10% to 27% of Total Cost

Lab Building HVAC Retrofits



- 60% of the \$60 million program
- 42% of the \$6 million saved
- Variable air volume, demand-based HVAC control


Case Study: Pacific Hall

- Built in 1993
- 185,000 GSF
- Chemistry & Biology Research Labs
- 230 chemical fume hoods
- Annual Energy Bill: \$1.3M (at mixed cogen + SDG&E rates)




Case Study: Pacific Hall


- Optimized air change rates
 - (12-15 ACH to 4-6 ACH)
- Occupancy sensors
- Fume hood
- Incorporat



Pacific Hall Results



Pacific Hall's New Baseline



MBCx / Retrofit Hybrids

- Vigilent HVAC Control – Poor Man's VAV
- Cypress Wireless Pneumatic Thermostats

Vigilent Control Installation

- Install new motors and VFDs on every AHU Fan
- Upgraded Johnson Controls BMS to BACNet Compatible Extended Architecture
- Tied Vigilent Server to Johnson Controls via BACNet

The screenshot displays a BMS software interface. On the left is a tree view showing the hierarchy of server rooms and air handlers. The right pane shows a 'Summary' table for 'LIBAH2-3 (Mech Room 2040)'.

Status	Item	Value	Description
	AH2-3-ENA	On	
	LIB.CP-10.AH-2.2.ZNCLGPB	40.0 deg F	Zone Cooling Proportional Band
	LIB.CP-10.AH-2.2.ZNCLGINT	10.0 seco...	Zone Cooling Integral Time
	LIB.CP-10.AH-2.2.ZNHTGPB	-40.0 deg F	Zone Heating Proportional Band
	LIB.CP-10.AH-2.2.ZNHTGINT	10.0 seco...	Zone Heating Integral Time
	LIB.CP-10.AH-2.2.ZNDH-PB	10.0 %RH	ZNDH Proportional Band
	LIB.CP-10.AH-2.2.ZNDH-INT	0.0 secon...	ZNDH Integral Time
	LIB.CP-11.AH-2.3.SYS-SHUT	Run	System Shutdown Mode
	LIB.CP-11.AH-2.3.SUP-SS	On	Supply Fan Start Stop
	LIB.CP-11.AH-2.3.SUP-STS	On	Supply Fan Status
	LIB.CP-11.AH-2.3.RET-SS	On	Return Fan Start Stop
	LIB.CP-11.AH-2.3.RET-STS	On	Return Fan Status
	LIB.CP-11.AH-2.3.OARA-DPR	Open	Osa Ra Damper Command
	LIB.CP-11.AH-2.3.RDPR-STS	Open	Return Air Damper Status
	LIB.CP-11.AH-2.3.EXH-DPR	Close	Exhaust Damper Command
	LIB.CP-11.AH-2.3.SA-T	74.6 deg F	
	LIB.CP-11.AH-2.3.MA-TMP	74.4 deg F	Mixed Air Temp
	LIB.CP-11.AH-2.3.RA-TMP	73.8 deg F	Return Air Temperature
	LIB.CP-11.AH-2.3.SF-SPD	70.0 %	Supply Fan Speed


Vigilant HVAC Control System

- Watches all zone temperatures
- If 3 or more zones are unsatisfied, it increase fan speed
- If fewer than 3 zones are unsatisfied, it slows fan speed
- Assumes that when most zone temps > setpoint, AHU is in “cooling mode”, and vice versa
- Minimum fan speed to maintain min ventilation requirements, or higher, based on comfort needs

	Cold	Good	Watch	Hot	Unreliable	LEGEND			
	Current Values		Current Setpoints				Auto-Cal		
Location *	Top -	Bottom *	Low *	High *	MAC *	Profile *	Low *	High *	
Room 475 W	78.6	-	72.1	78.1	00-DF-B2	SENSOR	<input checked="" type="checkbox"/> 72.1	<input checked="" type="checkbox"/> 78.1	
Room 182 W	75.9	-	70.8	76.8	00-CB-42	SENSOR	<input checked="" type="checkbox"/> 70.8	<input checked="" type="checkbox"/> 76.8	
Room 278 W	75.9	-	67.5	75.0	00-E0-37	SENSOR	<input checked="" type="checkbox"/> 67.5	<input checked="" type="checkbox"/> 75.0	
Room 490 W	75.9	-	70.4	76.4	00-CB-77	SENSOR	<input checked="" type="checkbox"/> 70.4	<input checked="" type="checkbox"/> 76.4	


Vigilant Energy Savings

Monthly Energy Usage for Cruise Control Library Pre & Post Project



Cypress Wireless Pneumatic Tstats

McGill-Mandler Hall Building Electric Demand Before and after WPT installation




ilding.
er.

Lessons Learned

- Periodic Checking of Energy Data
- Ongoing Findings Log Tracking
- Tight Coordination with HVAC Techs & Ongoing Construction Projects
- Unforeseen Variables Impacting Energy
 - Exhaust Stack Velocity Requirements
 - High Heat Load Rooms Driving SAT & SP
- Worth Additional \$ to Cover Project Management
- Creative Technology Justification
- Contracting of MBCx Repairs


Additional Energy Efficiency Projects

- Central Plant Heat Recovery (\$1M saved per year)
- Light Fixture & Control Retrofits (\$200K saved per year)
- Bi-level Parking Lot Lighting



Future Projects

- Wireless lighting control
- Room temperature biology sample storage & freezer management
- Wireless occupancy-based HVAC control



Courtesy of © Adura Technologies

Anna Levitt
alevitt@ucsd.edu
858-534-8336

